

**TECHNICAL DATA** 

# Fluke FEV100 Adapter Kits for Electric Vehicle Charging Stations



VEHICLE SIMULATION CP Control Pilot state simulation tests different charging states

**GROUNDING PROTECTION** PE Pre-Test for dangerous voltage

GFCI TESTING Stay protected from and check risk of electric shock

COMPATIBILITY Integrates into Fluke portfolio of test and measurement tools

**SAE J1772** Complies with North American standards

# Test the functionality and safety of electrical vehicle charging stations, easily and reliably

Test the safety and performance of type 1 or connector for Tesla<sup>™</sup> station, level 1 or level 2 electric vehicle ac charging stations (EVSEs) with the Fluke FEV100. This test adapter simulates the presence of an electrical vehicle, allowing you to conduct tests in combination with appropriate test instruments such as a digital multimeter or oscilloscope. Use the FEV100 to verify an EVSE is working properly after install and during periodic maintenance, or troubleshoot an EVSE if it is not delivering the appropriate charge.

# Safety

EVSE charging cables may become damaged over the course of use, increasing electric shock risks to users. Stay protected from and check risk of electric shock with the GFCI trip test. This function verifies the breaker of the EVSE is connected by detecting ground faults. Additionally, the PE grounding protection pre-test verifies that there is no presence of dangerous voltage at the ground terminal.

# Simplicity and convenience

Perform a variety of tests including ground fault checks, insulation of wires, measuring voltage and duty cycle to see max current available for charging all with one adapter that safely integrates with the Fluke portfolio of test and measurement tools. There is no need to bring an electric vehicle onsite for EVSE troubleshooting: the adapter acts as an electric vehicle when connected to an EVSE for easy performance and maintenance testing.



# How to test a charging station

Once an EVSE recognizes it is connected to a "car" and is ready for charging, the adapter tests if the EVSE is performing the way it should be.

- 1. Perform the safety grounding protection pretest to verify that no dangerous voltage is present in the grounding circuit. If the indicator lights up, it is possible that the electrical wiring has been set up improperly or there is a grounding malfunction. In this instance stop further testing immediately and check for a possible wiring fault of the ground conductor.
- 2. Verify station output voltage using an additional meter, such as the 87V digital multimeter.
- 3. Verify station maximum preset charge current using CP terminals and a meter with a duty cycle function or an oscilloscope.
- 4. Simulate the error states as described in the SAE J1772 standard: CP error "E", GFCI trip test, and grounding error.

### CP error "E" simulation

The standard SAE J1772 defines Error "E" as a state when charging station is: disconnected from vehicle, disconnected from utility, there is a loss of utility power or control pilot is short to control pilot reference (ground). This error simulation tests the station to ensure that if there is an issue with the CP of the vehicle, the station and utility will not supply a charge to the vehicle.

### GFCI

Each EVSE is required to be equipped with GFCI protection. On many stations, the GFCI protection is fully automatic and does not need a manual reset after the GFCI circuit is tripped.

### **Ground Error (Ground Fault) simulation**

The Ground Error button simulates an interruption of the ground conductor. As a result, the pending charging process is aborted and new charging processes are prevented.

Advanced tests such as insulation resistance, power quality, analysis of the control pilot waveform and loop impedance can also be done using the adapter in conjunction with appropriate test and measurement equipment.

# Verifying charging voltage with vehicle simulation

The CP state rotary switch selector simulates various vehicle states when the test adapter is connected to the charging station. Vehicle states are simulated with different resistances connected between CP and PE conductors.





Marking of vehicle state	Electric Vehicle (EV) State	Resistance between CP and PWE	Voltage at CP terminal
A	EV not connected	Open (∞)	±12 V 1 kHz
В	EV connected, not ready to charge	2.74 kΩ	±9 V/-12 V 1 kHz
С	EV connected, ventilation not required, ready to charge	882 Ω	+6 V/-12 V 1 kHz
D	EV connected, ventilation required, ready to charge	246 Ω	±12 V 1 kHz

Correlation between resistance and vehicle states



# Specifications

General specifications		
Input voltage	UL1/N = 120 V, UL2/N = 120 V, UL1/L2 = 208 V, 60 Hz (three-phase system) or UL1/N = 120 V, UL2/N = 120 V, UL1/L2 = 240 V, 60 Hz (single-phase system), $\pm$ 10 % voltage fluctuations from nominal 2	
EV connector	SAE J1772 socket (type 1, 5P single-phase) Connector for Tesla™ station	
Internal power consumption	2 W max.	
Operating temperature	-4 °F to 104 °F (-20 °C to 40 °C)	
Storage temperature	-4 °F to 122 °F (-20 °C to 50 °C)	
Operating humidity range	10 % to 85 % relative humidity non-condensing	
Storage relative humidity	0 % to 85 % non-condensing	
Operating altitude	6561 ft (2000 m) max.	
Dimensions (H $\times$ W $\times$ D)	Approx. 8.66 x 4.33 x 1.77 in (220 x 110 $\times$ 45 mm) without cable assembly	
Weight	Approx. 4.4 lb (2 kg)	
Safety standards	IEC 61010-1, Pollution Degree 2 IEC 61010-2-030	
Measurement category	CAT II 250 V	
IP protection class	IP54	
Electromagnetic Compatibil	ity (EMC)	
Electromagnetic Compatibil	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments.	
Electromagnetic Compatibil International USA (FCC)	<ul> <li>ity (EMC)</li> <li>IEC 61326-1: Basic Electromagnetic Environment</li> <li>CISPR 11: Group 1, Class A</li> <li>Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equipment itself.</li> <li>Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that supplies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances.</li> <li>Caution: This equipment is not intended for use in residential environments.</li> <li>47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103.</li> </ul>	
Electromagnetic Compatibil International USA (FCC) Functions	<ul> <li>ity (EMC)</li> <li>IEC 61326-1: Basic Electromagnetic Environment</li> <li>CISPR 11: Group 1, Class A</li> <li>Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equipment itself.</li> <li>Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that supplies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances.</li> <li>Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments.</li> <li>47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103.</li> </ul>	
Electromagnetic Compatibil International USA (FCC) Functions CP States	<ul> <li>ity (EMC)</li> <li>IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A</li> <li>Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself.</li> <li>Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances.</li> <li>Caution: This equipment is not intended for use in residential environments.</li> <li>47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103.</li> </ul>	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E"	<ul> <li>ity (EMC)</li> <li>IEC 61326-1: Basic Electromagnetic Environment</li> <li>CISPR 11: Group 1, Class A</li> <li>Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equipment itself.</li> <li>Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that supplies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances.</li> <li>Caution: This equipment is not intended for use in residential environments.</li> <li>47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103.</li> <li>A, B, C, D</li> <li>On/off</li> </ul>	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E" PE Error	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments. 47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103. A, B, C, D On/off On/off	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E" PE Error GFCI Test	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments. 47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103. A, B, C, D On/off On/off Yes, test resistor of 2 kΩ connected between L1 and PE, time limitation 40 ms	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E" PE Error GFCI Test PE Pre-Test (typical)	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments. 47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103. A, B, C, D On/off On/off Yes, test resistor of 2 kΩ connected between L1 and PE, time limitation 40 ms Visible indication >30 V on PE conductor	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E" PE Error GFCI Test PE Pre-Test (typical) Outputs (for test purpose on	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments. 47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103. A, B, C, D On/off Ves, test resistor of 2 kΩ connected between L1 and PE, time limitation 40 ms Visible indication >30 V on PE conductor <b>Ly</b> )	
Electromagnetic Compatibil International USA (FCC) Functions CP States CP Error "E" PE Error GFCI Test PE Pre-Test (typical) Outputs (for test purpose on Measuring terminals L1, L2/N, PE	ity (EMC) IEC 61326-1: Basic Electromagnetic Environment CISPR 11: Group 1, Class A Group 1: Equipment has intentionally generated and/or uses conductively-coupled radio frequency energy that is necessary for the internal function of the equip- ment itself. Class A: Equipment is suitable for use in all establishments other than domestic and those directly connected to a low-voltage power supply network that sup- plies buildings used for domestic purposes. There may be potential difficulties in ensuring electromagnetic compatibility in other environments due to conducted and radiated disturbances. Caution: This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments. 47 CFR 15 subpart B. This product is considered an exempt device per clause 15.103. A, B, C, D On/off On/off Yes, test resistor of 2 kΩ connected between L1 and PE, time limitation 40 ms Visible indication >30 V on PE conductor Iy) Max. 250 V 50/60 Hz, CAT II 250 V	



## **Ordering information**

Fluke FEV100/TY1 KIT Adapter Kit for Electric Vehicle Charging Stations

### Included

- Fluke FEV100/BASIC Test Adapter
- Fluke FEV-CON/TY1 Type 1 Connector and Cable
- Soft Carrying Case
- Fluke 87V Industrial Multimeter
- TL75 Test Leads
- AC175 Alligator Clips
- Holster with tilt-leg, test lead storage
- 80BK Temperature Probe
- 9V Battery
- Fluke TL224 SureGrip™ Insulated Test Leads





Fluke FEV100/TY1 KIT2 Adapter Kit for Electric Vehicle Charging Stations

### Included

- Fluke FEV100/BASIC Test Adapter
- Fluke FEV-CON/TY1 Type 1 Connector and Cable
- Soft Carrying Case
- Fluke 125B Industrial ScopeMeter®
- Shielded test leads with black ground leads
- Test lead black (for grounding)
- Hook clips (red, blue)
- Banana-to-BNC adapters (black)
- USB angled adapter
- WiFi USB Adapter\*
- Switch Mode power supply, Adapter/battery charger
- Rechargeable Li-ion battery pack
- Fluke 87V Industrial Multimeter
- TL75 Test Leads
- AC175 Alligator Clips
- Holster with tilt-leg, test lead storage
- 80BK Temperature Probe
- 9V Battery
- Fluke TL224 SureGrip<sup>™</sup> Insulated Test Leads



# **Ordering information (continued)**

Fluke FEV100/TY1 and Tesla<sup>™</sup> Adapter Kit for Electric Vehicle Charging Stations

### Included

- Fluke FEV100/BASIC Test Adapter
- Fluke FEV-CON/TY1 Type 1 Connector and Cable
- Fluke FEV-CON-TSL Tesla™ Type Connector and Cable
- Soft Carrying Case

Connector for Tesla<sup>™</sup> Station can also be purchased separately

Please note the Fluke connector for Tesla<sup>TM</sup> station does not work with the Tesla<sup>TM</sup> Superchargers or any other DC fast charging stations. Do not attempt to use this adapter with DC fast chargers.

Tesla is a registered trademark of Tesla, Inc.





Fluke FEV100 Adapter Kit for Electric Vehicle Charging Stations

### Included

- Fluke FEV100/BASIC Test Adapter
- Fluke FEV-CON/TY1 Type 1 Connector & Cable
- Soft Carrying Case

The FEV100 is compatible with the Fluke portfolio of test and measurement tools. Take critical measurements such as voltage, waveform, loop impedance and resistance.

### **Recommended tools for use with the FEV100**

- 87V Industrial Multimeter
- 376 FC True-RMS Clamp Meter with iFlex® Flexible Current Probe
- 1587 FC Insulation Multimeter
- 1738 Three-Phase Power Quality Logger
- 1630-2 FC Earth Ground Clamp
- BT521 Advanced Battery Analyzer
- 1664 FC Installation Multifunction Testers
- 125B Industrial ScopeMeter® Handheld Oscilloscope

Fluke. Keeping your world